

iii. A) Means of Escape.

Sl.No.	No.of Staircases	Width in Meters	Total width.
	Internal 1 No.	1.50 Mtrs.	1.50 Mtrs.
	External 1 No.	1.25 Mtrs.	1.25 Mtrs.
	Total: 2 Nos.	2.75 Mtrs.	2.75 Mtrs.

4. The management has remitted Fire precaution Fee of Rs.10,000/- Challan No.11840, dt: 14-10-2015 at State Bank of Hyderabad Branch: Wanaparthy .
Fire Safety Measures:

Sl. No.	Fire Safety Measures	Required as per Table 23 of NBC of India 2005.	Provided	Deficiency
1.	2.	3.	4.	5.
1.	Fire Extinguishers	09 Nos.	12 Nos.	-Nil-
2.	Fire Buckets.	16 Nos.	20 Nos.	-Nil-
3.	Hose Reel	3 Nos	3 Nos.	-Nil-
4.	Terrace Tank 5000 Ltrs.	1 No.	1 No.	-Nil-
5.	Booster Pump 450 LPM	1 No.	1 No.	-Nil-

5. The Fire Safety systems were tested by me during the inspection and performance found satisfactory.

6. Therefore No Objection Certificate for occupancy to the above Educational Building of **Gayathri Educational Society (Gayathri D.Ed & B.Ed College) situated at H.No.261/2, Tadiparthi (V) Gopalpet (M) Mahabubnagar District** is renewed subject to the following conditions.

- i. All the Fire protection arrangements shall be maintained in good condition as seen during inspection.
- ii. All the escape/exit routes shall not be kept locked/blocked or encroached.
- iii. All the occupants must know the correct method of operation of the Fire Fighting system installed.
- iv. Any loss of life or property due to non-functioning of Fire safety measures and other installations shall be the responsibility of the management.
- v. All students /Staff members of the institution shall be trained to operate the Fire safety equipments during emergency.
- vi. Addition/alteration, if any in the building may be obtained with prior permission from this Department.
- vii. Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

6. This renewal of NOC is valid up to 14-10-2016.

Yours faithfully


Station Fire Officer
Wanaparthy, 15-10-2015
Station Fire Officer
Fire Station, Wanaparthy